



JOINT UTILITIES OF NEW YORK

CGPP: Generation Siting Methodology


June 17, 2024 EPPAC Meeting



Agenda

- High-level context: practicable siting methodology
- Zonal to nodal placement of generation specified in capacity expansion modeling
 - Sequence of considerations
 - Process
- Land use constraints, proximity to transmission
- Siting DER
- Q&A

Siting Methodology: Generator Placement



Planning methodology co-optimizing generation capital cost and production cost to determine a least cost future generation capacity buildout under various planning scenarios using detailed generation, transmission, load, and cost data, forecasts, and policies. (NYISO)

Nodal placement (*i.e.*, at the bus level, reflecting headroom, land use constraints, etc.) enables a power flow model to examine the grid to identify where transmission congestion is likely to occur.

Zonal to Nodal Placement: Sequence of Considerations

- CGPP objective: determine least-cost investment and dispatch solution
 - Placement within DACs to be monitored closely throughout the analysis
- Requirement: Placement of resources identified in the capacity expansion modeling work (NYISO)
 - *E.g.*, 1200 MW blocks, ~15 GW of solar PV in Zone E, *etc.*
 - Block sizes may be smaller on the lower voltage/115kV system
- Initial development: NYISO Interconnection Queue
 - But: what proportion of the queue is shed naturally as the economics become clear?
 - Model all interconnection queue projects at stage 6 or later.* Consider simplifying the models to aggregate generation to the POI instead of the full model build out with all the extra collector buses and discrete generators.

* *Known physical feasibility considerations will apply to queue projects at stage 6 or later. Queue reform may affect the way this methodology is applied. The JU plan to model sufficiently advanced interconnection queue projects: Stage 6* (Approved SRIS) or later in the preceding process; a passed infeasibility screening and cluster study in the new process. The JU will attempt to simplify models to aggregate generation to interconnection locations to avoid a full model build out with all the extra collector buses and discrete generators.*

Zonal to Nodal Placement: Sequence of Considerations (continued)


- NYISO Interconnection queue (continued)
 - Evaluate the split between projects in the queue (in each zone) by voltage level:
 - Apply this as an assumption for siting capacity from the buildout scenarios
 - Example: based on review of the NYISO queue, resources beyond the queue could be placed in Zone X: 40% at 345kV, 60% on lower-voltage system
- Renewables, DEFs: should different approaches apply?
 - JU Methodology:
 - Same approach but for placement in DACs, *i.e.*:
 - Renewables and fuel cells may be placed in DACs
 - However, no new combustion units will be placed in DACs
 - Combustion DEFs may be placed at existing fossil (combustion) facilities
 - Up to the existing nameplate capacity
 - Incremental capacity may not be sited in a DAC

Zonal to Nodal Placement: Sequence of Considerations (continued)

- Guardrails: size of individual projects at a single location
 - [JU Methodology](#)*:
 - ***Minimum resource type block size of 100 MW***
 - ***Maximum aggregate amount of generation at any location*** (Note: storage would not offset these maximum capacity levels; these levels would cap the capacity of storage.)
 - 600 MW at 115kV (3000A); 700 MW at 138kV (3000A); 1200 MW at 230kV (3000A); 2400 MW at 345kV (4000A)
- Coordination between the utility/utilities and developers
 - [JU Methodology](#): Assume perfect coordination (i.e., developers build in the locations the JU identify in the study); solutions will unlock generation at specific locations, which will be made public in Stage 6, headroom updates, etc. subject to CEI limitations.

* *Subject to the profile of specific locations. Resource land-use considerations (e.g., for utility-scale PV) must be considered as well.*

Siting Methodology Illustrated



(Detail on each of these steps appears on the next slides.)

Zonal to Nodal Placement: Process

1. Start with NYISO interconnection queue

- Place all resources at Stage 6 or later at the POI at which that project is currently planned
- Supply curve data and county-level capacity expansion results to be considered
 - Example: skip a resource if it is located in an area that is already saturated to levels of Cap Ex models

2. Consume available/remaining headroom on transmission/local transmission buses*

- Prioritized set of stations (county by county) where capacity can/should be located
- Criteria for prioritization:
 - Existing/planned stations that are expandable
 - Existing generation resources retired/retiring
 - Note: *Re-powering is assumed within the State Scenario, specifically for hydrogen combustion*
 - Stations with space
 - Evaluate stations that may have headroom, but are not physically suitable for interconnecting resources
 - Interconnect to any lines that lead to that station and that have line-level headroom

* For this CGPP cycle, the Joint Utilities will use headroom calculations presented in the Feb 1, 2024 update filing.

Zonal to Nodal Placement: Process (continued)

3. Once stations are exhausted, look at line locations

- Is the system able to accommodate additional capacity?
- Assumptions re: renewable capacity factor (simultaneous)
- Identify locations where a mid-line interconnection point may be created
 - Interconnection points are assumed to be 3-breaker ring bus
 - Up to summer LTE rating of the existing line

4. On exhaustion of available headroom:

- Place incremental resources at sites where resources have already been placed, but the interconnection threshold for a given location (*noted on slide 6*) has not yet been reached
- Apply engineering judgement:
 - Consider: population density, flood zones, state parks/lands, etc. to select locations
 - Siemens strong bus analysis; screen out areas where interconnection is unlikely to be feasible


5. Post-placement check

Use available tools (e.g., supply curve, etc.) to validate placements

- Assumptions may need to change in the course of analysis of Step 3 (line location) decisions

Proximity to Transmission

- **Challenge:** Many stations are not expandable, but available land does exist
 - JU approach: Bisect lines, place generation on new lines so that it does not need to be placed at specific stations
- Evaluation of land-use constraints/restrictions
 - Based on NYSERDA Integration Analysis
- Upstate: Place large capacity bundles along existing lines, generally proximate to switching stations



Siting DER

- DER modeled separately as a reduction in load in power flow models
- DER siting assumptions will be informed by utilities' hosting capacity calculations and other tools

EXAMPLE:

- This forecast for solar resources is integrated into the load forecast for Scenario 2.
- It reflects a modification to the CaC 2022 Scenario 2: Strategic Use of Low-Carbon Fuels "High End Use Flexibility" load forecast.

Solar Roadmap Base	2030	2035	2040	2045	2050
A-F	7,196	9,773	12,608	16,001	20,038
GHI	1,118	1,208	1,307	1,426	1,567
J	754	1,009	1,290	1,625	2,025
K	1,231	1,511	1,819	2,188	2,626
Total	10,299	13,501	17,023	21,239	26,256

Q&A



nationalgrid

 Orange & Rockland
Rockland Electric Company

 conEdison

 PSEG LONG
ISLAND

People. Power. Possibilities.
Central Hudson
A FORTIS COMPANY 

